



8165 E Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Report No: L121911542TM30

Date: 12/24/2019







TM-30-15 REPORT

Report No:	L121911542TM30
Prepared For:	Vode Lighting 21684 8th Street East, Suite 700, Sonoma, CA 95476
Model Number:	707-Z3-48-Z-SO-359-U2-AL
Testing Lab:	Light Laboratory Inc.
Reference report No:	L121911542
Remark:	This report is based on the data from Light Laboratory Inc. report L121911542

Results Summary


Metric	Result	Notes
R_f	89	IES TM-30-15 Fidelity Index
R_g	98	IES TM-30-15 Gamut Index
CIE R_a	94	CIE Test Color Method General Index
R_9	58	CIE Test Color Method Sample Nine Score
$R_{f,skin}$	93	Average of CES15 and CES18 (skin)
CCT	3415	Correlated Color Temperature
D_{uv}	-0.0005	Distance from the blackbody locus
x	0.4096	CIE 1931 chromaticity coordinate
y	0.3917	CIE 1931 chromaticity coordinate
u	0.2381	CIE 1960 chromaticity coordinate
v	0.3415	CIE 1960 chromaticity coordinate
u'	0.2381	CIE 1976 chromaticity coordinate
v'	0.5123	CIE 1976 chromaticity coordinate





Hue Bin	R_f	Graphic shifts (%)	
		Chroma	Hue
1	88	-5%	1%
2	92	-2%	2%
3	93	-1%	2%
4	93	-3%	-1%
5	91	-6%	0%
6	96	-1%	1%
7	91	-4%	3%
8	96	0%	2%
9	89	0%	7%
10	86	1%	9%
11	86	4%	7%
12	87	7%	-2%
13	89	1%	-7%
14	85	3%	-11%
15	84	-2%	-7%
16	84	-3%	-7%

Hue Angle Bin vs. Fidelity Index



Hue Angle Bin vs. Change of Chroma

